

Date: April 6, 2010 9:00 AM

**Boettcher Center – EVstudio project #0939
Addenda #3**

Changes to Bid Timeline - No

1. Question (FDS): There are no powered door holders shown on plans or required fro this project. **As shown on the fire alarm drawings, no powered door holders are required on this project. Please disregard this section.**
2. Question (FDS): The installer qualification as a NICET III is not required for Denver and will add considerable cost. Do you really want this? **As stated in the specification, the purpose of this portion of the specification is to ensure that the design of the fire alarm system is reviewed and installed under the direction of a NICET III level certified installer or higher. The installation work done on the project does not have to performed solely by NICET III level certified installers.**
3. Question (FDS): The only manufacturer approved for this project is Notifier 640 Onyx. **Please follow the direction given on the drawings which requires that a NOTIFIER 640 panel be used for the project. No other fire alarm panel manufacturer will be accepted.**
4. Question (FDS): Only one manual pull station is required per Denver amendments, do you want us to provide the five shown? **Per Denver amendments, only one pull station is required. However owner has requested one pull station at all exit doors. Please provide as shown.**
5. Question (FDS): D thru I refers to speakers. These are not required for this occupancy. **As shown on the fire alarm drawings, no speakers will be required. Please disregard this section.**
6. Question (FDS): Firefighters Telephone is not required. **As shown on the fire alarm drawings, no firefighters' telephones will be required. Please disregard this section.**
7. Question (FDS): The remote annunciator describes a display same as the FACP. Denver does allow there types at this time. We would suggest using a directory type with a graphic map per Denver amendment 907.9.1. **A directory type annunciator with a graphic map per Denver amendment 907.9.1 will be acceptable, pending approval from Denver Fire Department.**
8. Question (FDS): A digital transmitter is not required. We are to reuse the existing SK 5104. **The reuse of the existing SK 5104 transmitter will be acceptable.**
9. Question (FDS): A radio transmitter is not required. **As shown on the fire alarm drawings, no radio transmitter will be required. Please disregard this section.**
10. Question (FDS): A listed printer is not required. **As shown on the fire alarm drawings, no listed printer will be required. Please disregard this section.**
11. Question (FDS): 1 a thru b – A one year warranty is standard after system acceptance test with the Fire Dept. This section describes multiple tests not required by code.

Please verify if D.U. wants these extra tests. **Provide tests as required by NFPA 72 and the International Codes including Denver amendments.**